

UST Checklist

Installation: Building:
Tank No.(s): Tank Material: Steel Fiberglass
POC: Other
Phone:

Tank(s) are registered (information is correct and current) Yes No

Cathodic Protection (steel tanks and piping only) Yes No N/A

Date of last inspection
Date of next inspection Every three years

Tank Release Detection

Tanks must be monitored at least every 30 days for releases using one of the methods listed in subsection 4 through 8 of 9 VAC25-580-160: Type of Tank Release Detection

Subsection 4: Automatic tank gauging Yes No

The automatic product level monitor test can detect a 0.2 gallon per hour leak rate from any portion of the tank and inventory control per Subsection 1 9VAC25-580-160

Make and model number:

Subsection 5: Vapor Monitoring Yes No

Subsection 6: Groundwater Monitoring Yes No

Subsection 7: Interstitial Monitoring Yes No

Subsection 8: Other Methods Yes No

Release detection system is operating properly: Yes No

Performed monthly leak test (every 30 days): Yes No Date:

Evidence of a release: Yes No Date reported:

Type of Piping

Pressurized Piping: Yes No N/A

Equipped with automatic or mechanical line leak detectors?

Automatic Mechanical N/A

Date of last annual line tightness test:

Date of next scheduled annual line tightness test:

Suction Piping: Yes No N/A

Use of line tightness tests or monthly monitoring: line tests monthly monitoring

Date of last line tightness test: N/A

Date of next schedule line tightness test (every three years): N/A

Gravity Piping: Yes No N/A

Other Inspection Items

Is spill prevention equipment installed and operating properly? Yes No N/A

Is overfill equipment installed and operating properly? Yes No N/A

Check condition of fill cap seals. If aged and show cracks, hardness, etc, replace immediately.

Is there an Emergency Spill Kit on site? Yes No

Was the UST internally lined? Yes No

UST internal lining inspection (required within 10 years of installation and every five years thereafter)

Date internally lined: N/A Date of next inspection:

Notes:

Inspector:

Date

KEEP A COPY OF ALL TESTS ON FILE